

NCE Environmental Consultants

November 28, 2019

Mr. Kevin Perretta
Superintendent of Buildings and Grounds
St. Lawrence-Lewis BOCES
40 West Main St.
Canton, New York 13617

Re: 2019 Fire Inspections

Dear Mr. Peretta:

I have completed the fire inspections of all the buildings in the BOCES and the following violations were noted. It is required that these violations be corrected in order to receive a certificate of occupancy.

NORWOOD

Seaway Area Tech Center

1. Item 12E1 Unapproved electric heater Cosmo.
2. Item 12I1 Multi plug adapter in room 3.
3. Item 15A2 Chairs/couches in hallway entrance and by IT hallway.
4. Item 17H2 Emergency light not working by entry and IT hallway.

Learning Resource Center – No violations noted

MFD Bldg. – Northeast

1. Item 17H2 Emergency light by entrance not working.

GOUVERNEUR

Southwest Tech – No violations noted.

Storage Bldg. SW Tech – No violations noted.

Small Storage Bldg. – Southwest Tech – No violations noted.

**36173 NYS Rt. 12E Clayton, New York 13624
315-654-5077**

Large Storage Bldg. Southwest Tech – No violations noted.

OGDENSBURG

Northwest Occ. Cnt.

1. Item 15A2 Tables in entry lobby.
2. Item 17H2 Emergency lights in Criminal Justice and by room 132 not working.
3. Item 17L1 Exit light not working in Welding.

NW Tech/Child Care – No violations noted.

Activity Center

1. Item 15A2 Windows in door are covered in two locations.
2. Item 17H2 Emergency light by main entrance not working.

Storage Bldg. – Northwest – No violations noted

CANTON

Educational Services Complex

1. Item 14A2 No proof of fire rating on throw rug in rooms 310 & 369.
2. Item 12J1 Improper use of extension cord in room 257. Surge to surge in room 340.

White Hill Tower Bldg. - No violations noted.

MASSENA

SLC Education Center - No violations noted.

Please advise me as to the date of the board meeting for the presentation of this report. You need to notify the public and the fire department as to the time and date of this meeting.

Sincerely yours,

John Warneck