

NCE Environmental Consultants

September 11, 2022

Mr. Kevin Perretta
Superintendent of Buildings and Grounds
St. Lawrence-Lewis BOCES
40 West Main St.
Canton, New York 13617

Re: 2022 Fire Inspections

Dear Mr. Perretta:

I have completed the fire inspections of all the buildings in the BOCES and the following violations were noted. It is required that these violations be corrected in order to receive a certificate of occupancy.

NORWOOD

Seaway Area Tech Center

1. Item 10A2 Rescue window sign missing in Staff room.
2. Item 12E1 Exposed wire overhead in HVAC shop.
3. Item 12J1 Appliances plugged into power strip in New Visions-Nursing.
4. Item 13B2 Ansul system pull station/hoods need to be identified.
5. Item 17H2 Emergency light not working in Media Center.

Learning Resource Center – Closed in accordance with regulations.

MFD Bldg. – Northeast – No violations noted.

GOUVERNEUR

Southwest Tech

1. Item 10A2 Exit directions missing throughout the building.

Storage Bldg. SW Tech – No violations noted.

Small Storage Bldg. – Southwest Tech – No violations noted.

Large Storage Bldg. Southwest Tech – No violations noted.

**36173 NYS Rt. 12E Clayton, New York 13624
315-654-5077**

OGDENSBURG

Northwest Occ. Center

1. Item 3B1 No boiler inspection found.
2. Item 16B2 Fire extinguisher missing in 306.
3. Item 17H2 Emergency light not working in 119A, 121, 127A & Create room.

NW Tech/Child Care – No violations noted.

Activity Center

1. Item 17H2 Emergency light not working in left office and adult ed. classroom.

Storage Bldg. – Northwest - No violations noted

CANTON

Educational Services Complex

1. Item 12J1 Appliances plugged into power strip in breakroom and by 345. Improper use of an extension cord in 335.
2. Item 12I1 Multiplug in DS's conference room.

White Hill Tower Bldg. - No violations noted.

Please advise me as to the date of the board meeting for the presentation of this report. You need to notify the public and the fire department as to the time and date of this meeting.

Sincerely yours,

John Warneck