

NCE Environmental Consultants

July 29, 2023

Mr. Kevin Perretta
Director of Facilities
St. Lawrence-Lewis BOCES
40 West Main St.
Canton, New York 13617

Re: 2023 Fire Inspections

Dear Mr. Perretta:

I have completed the fire inspections of all the buildings in the BOCES and the following violations were noted. It is required that these violations be corrected in order to receive a certificate of occupancy.

NORWOOD

Seaway Area Tech Center

1. Item 17L1 Exit light not working 155.

Learning Resource Center - No violations noted. Cold storage.

MFD Bldg. – Northeast – No violations noted.

GOUVERNEUR

Southwest Tech

1. Item 17H2 Emergency light not working 115.

Storage Bldg. SW Tech – No violations noted.

Small Storage Bldg. – No violations noted.

Large Storage Bldg. – No violations noted.

OGDENSBURG

**36173 NYS Rt. 12E Clayton, New York 13624
315-654-5077**

Northwest Occ. Center

1. Item 4A2 Flammables improperly stored in Natural Resources.

NW Tech/Child Care – No violations noted. Cold storage

Activity Center - No violations noted.

Storage Bldg. – Northwest - No violations noted

CANTON

Educational Services Complex

1. Item 12J1 Appliances plugged into power strip in 217. Improper use of an extension cord in 251.

IDA Building - No violations noted.

White Hill Tower Bldg.

1. Item 9A2 Excessive vegetation around building.

Please advise me as to the date of the board meeting for the presentation of this report. You need to notify the public and the fire department as to the time and date of this meeting.

Sincerely yours,

John Warneck