

NCE Environmental Consultants

January 8, 2019

Mr. Kevin Perretta
Superintendent of Buildings and Grounds
St. Lawrence-Lewis BOCES
40 West Main St.
Canton, New York 13617

Re: 2018 Fire Inspections

Dear Mr. Peretta:

I have completed the fire inspections of all the buildings in the BOCES and the following violations were noted. It is required that these violations be corrected in order to receive a certificate of occupancy.

NORWOOD

Seaway Area Tech Center

1. Item 12J1 Appliances plugged into power strip in 3.
2. Item 17C2 Decorations on door in Human Services & Education lab school.

Learning Resource Center – No violations noted

MFD Bldg. – Northeast

1. Item 17C2 Door light covered in 106.
2. Item 17H2 Emergency light by entrance not working.

GOUVERNEUR

Southwest Tech

1. Item 12I1 Multi-plug in Heavy Equipment classroom.

Storage Bldg. – No violations noted.

Small Storage Bldg. – Southwest Tech – No violations noted.

Large Storage Bldg. Southwest Tech – No violations noted.

**36173 NYS Rt. 12E Clayton, New York 13624
315-654-5077**

OGDENSBURG

Northwest Occ. Cnt.

1. Item 17H2 Emergency light not working in Building trades.

NW Tech/Child Care

1. Item 17H2 Numerous emergency lights not working. Need to check all.

Activity Center

1. Item 16B2 Fire extinguisher needed in kitchen.
2. Item 17H2 Emergency light by main entrance not working.

Storage Bldg. – Northwest – No violations noted

CANTON

Educational Services Complex

1. Item 17C2 Paper on door room 372.

White Hill Tower Bldg. - no violations noted.

MASSENA

SLC Education Center - no violations noted.

Please advise me as to the date of the board meeting for the presentation of this report. You need to notify the public and the fire department as to the time and date of this meeting.

Sincerely yours,

John Warneck

