NCE Environmental Consultants

November 3, 2020

Mr. Kevin Perretta Superintendent of Buildings and Grounds St. Lawrence-Lewis BOCES 40 West Main St. Canton, New York 13617

Re: 2020 Fire Inspections

Dear Mr. Peretta:

I have completed the fire inspections of all the buildings in the BOCES and the following violations were noted. It is required that these violations be corrected in order to receive a certificate of occupancy.

NORWOOD

Seaway Area Tech Center

- 1. Item 12I1 Surge to surge in software development & Culinary.
- 2. Item 12K1 Cover plate missing in Culinary kitchen.

Learning Resource Center

1. Item 12E1Appliances plugged into a surge.

MFD Bldg. - Northeast

1. Item 12E1 Appliances plugged into surge in kitchen, Alt. GED & room. 123.

GOUVERNEUR

Southwest Tech

- 1. Item 12E1Appliances plugged into a surge in Heavy Equipment.
- 2. Item 12J1 Surge to surge in Heavy Equipment.
- 3. Item 12K1Cover plate missing in room 109.
- 4. Item 17D2 Exit light not working in Auto Tech.
- 5. Item 17H2 Emergency light not working by new wing hallway (2).

Storage Bldg. SW Tech – No violations noted.

Small Storage Bldg. - Southwest Tech - No violations noted.

Large Storage Bldg. Southwest Tech - No violations noted.

OGDENSBURG

Northwest Occ. Cnt.

Item 10A2
Item 12K1
Cover plate missing in Auto Shop (2).
Item 17D2
Exit light not working by fire door side entrance, by 129, by 133, by kitchen and in Building Trades.
Item 17H2
Item 19E1
Item 23B1
Exit directions missing in Graphics.
Exit light not working by fire door side entrance, by 129, by 133, by kitchen and in Building Trades.
Emergency light not working in kitchen.
Pipe Bollards required by gas entrance.
Carpet in Principals office does not met Fire code

NW Tech/Child Care

1. Item 17H2 Emergency light not working.

requirements.

Activity Center - No violations noted.

Storage Bldg. - Northwest - No violations noted

CANTON

Educational Services Complex

1. Item 12J1

Improper use of extension cord in rooms 356 & 359. Surge to surge in room 360.

White Hill Tower Bldg. - No violations noted.

MASSENA

Massena Mall

Please advise me as to the date of the board meeting for the presentation of this report. You need to notify the public and the fire department as to the time and date of this meeting.

Sincerely yours,

John Warneck