

NCE Environmental Consultants

September 29

Mr. Kevin Perretta
Superintendent of Buildings and Grounds
St. Lawrence-Lewis BOCES
40 West Main St.
Canton, New York 13617

Re: 2021 Fire Inspections

Dear Mr. Peretta:

I have completed the fire inspections of all the buildings in the BOCES and the following violations were noted. It is required that these violations be corrected in order to receive a certificate of occupancy.

NORWOOD

Seaway Area Tech Center

1. Item 12J1 Appliances plugged into power strip in Allied Health.
Improper use of an extension cord in Welding classroom.
2. Item 17H2 Emergency light not working in Media Center
3. Item 23A1 Combustible materials piled on stove in Health Careers.

Learning Resource Center

1. Item 17H2 Emergency light in Rec. room not working..

MFD Bldg. – Northeast – No violations noted.

GOUVERNEUR

Southwest Tech

1. Item 10A2 Exit directions missing throughout the building.
2. Item 16B2 Fire Extinguisher missing in Create classroom.

Storage Bldg. SW Tech

1. Item 16B2 Fire extinguisher missing.
2. Item 17D2 Exit sign missing.

Small Storage Bldg. – Southwest Tech – No violations noted.

36173 NYS Rt. 12E Clayton, New York 13624
315-654-5077

Large Storage Bldg. Southwest Tech

1. Item 17D2 Exit sign missing.

OGDENSBURG

Northwest Occ. Cnt.

1. Item 10A2 Exit directions missing throughout the building.
2. Item 12J1 Improper use of an extension cord in Allied Health.
3. Item 17H2 Emergency light not working in Media Center.

NW Tech/Child Care

1. Item 17H2 Emergency light not working.

Activity Center - No violations noted.

Storage Bldg. – Northwest - No violations noted

CANTON

Educational Services Complex

1. Item 16A2 Fire extinguisher not inspected by 220.

White Hill Tower Bldg. - No violations noted.

MASSENA

Massena Mall – No violations noted.

Please advise me as to the date of the board meeting for the presentation of this report. You need to notify the public and the fire department as to the time and date of this meeting.

Sincerely yours,

John Warneck