NCE Environmental Consultants

June 26, 2024

Mr. Kevin Perretta
Director of Facilities
St. Lawrence-Lewis BOCES
40 West Main St.
Canton, New York 13617

Re: 2024 Fire Inspections

Dear Mr. Perretta:

I have completed the fire inspections of all the buildings in the BOCES and the following violations were noted.

The Storage Building at SW Tech will require a re-inspection based on the severity of the violation Please let me know when the correction has been made at SW Tech so a re-inspection can be schedule.

It is required that these violations be corrected to receive a certificate of occupancy.

NORWOOD

Seaway Area Tech Center

1. Item 12J1 Appliances plugged into power strip in Records rm. & 210.

Learning Resource Center - No violations noted. Cold storage.

MFD Bldg. – Northeast

1. Item 12K1 Cover plate missing on outlet.

GOUVERNEUR

Southwest Tech – No violations noted.

Storage Bldg. SW Tech

- 1. Item 6F1 Building not neat& orderly.
- 2 Item 17A3 Blocked exit

Small Storage Bldg. – No violations noted.

Large Storage Bldg. - No violations noted.

OGDENSBURG

Northwest Occ. Center

1. Item 12K1	Cover plate missing in Data rm 132.
2. Item 16B2	Ansul system out of inspection.
3. Item 17H2	Emergency light not working in laundry rm. 206A.
4. Item 19E1	Pipe bollards required around outside electrical transformer
	and gas meter/entrance

NW Tech/Child Care - No violations noted. Cold storage/power off.

Activity Center

- 1. Item 12A1 Improper storage in electrical room.
- 2. Item 17H2Emergency light not working in back right room.

Storage Bldg. - Northwest

1. Item 16A2 Fire extinguisher missing.

CANTON

Educational Services Complex

1. Item 12J1 Improper use of an extension cord in 251 & 335.

Please advise me as to the date of the board meeting for the presentation of this report. You need to notify the public and the fire department as to the time and date of this meeting.

Sincerely yours,

John Warneck