

NCE Environmental Consultants

June 14, 2025

Mr. Kevin Perretta
Director of Facilities
St. Lawrence-Lewis BOCES
40 West Main St.
Canton, New York 13617

Re: 2025 Fire Inspections

Dear Mr. Perretta:

I have completed the fire inspections of all the buildings in the BOCES and the following violations were noted. It is required that these violations be corrected to receive a certificate of occupancy.

NORWOOD

Seaway Area Tech Center

1. Item 9D1 Items stored within 2' of the ceiling in Criminal Justice 201.
2. Item 15A2 Materials in hallway by 206.

Learning Resource Center - No violations noted. Cold storage.

MFD Bldg. – Northeast – No violations noted.

GOUVERNEUR

Southwest Tech – No violations noted.

Storage Bldg. SW Tech – No violations noted.

Small Storage Bldg. – No violations noted.

Large Storage Bldg. – No violations noted.

OGDENSBURG

**36173 NYS Rt. 12E Clayton, New York 13624
315-654-5077**

Northwest Occ. Center

1. Item 9D1 Items stored within 2' of the ceiling in Cosmetology.

NW Tech/Child Care – No violations noted. Cold storage/power off.

Activity Center – No violations noted.

Storage Bldg. – Northwest – No violations noted.

CANTON

Educational Services Complex

1. Item 12E1 Air freshener in Literacy Office.

Adult Ed. – IDA Building

1. Item 12E1 Appliance plugged into power strip in main office and upstairs office.
2. Item 12K1 Exposed wire by stairs in apprentice area.
3. Item 14B2 Another door or window required in back apprentice area with overhead door.

Please advise me as to the date of the board meeting for the presentation of this report. You need to notify the public and the fire department as to the time and date of this meeting.

Sincerely yours,

John Warneck