

NCE Environmental Consultants

May 20, 2026

Mr. Kevin Perretta
Director of Facilities
St. Lawrence-Lewis BOCES
40 West Main St.
Canton, New York 13617

Re: 2026 Fire Inspections

Dear Mr. Perretta:

I have completed the fire inspections of all the buildings in the BOCES on May 14 & 15, 2026 and the following violations were noted. It is required that these violations be corrected to receive a certificate of occupancy.

NORWOOD

Seaway Area Tech Center

- 1. Item 15A2 Materials stored in hallway by 133.
- 2. Item 15D2 Materials hanging from ceiling in 131.

Learning Resource Center - No violations noted. Cold storage.

MFD Bldg. – Northeast – No violations noted.

GOUVERNEUR

Southwest Tech

- 1. Item 12J1 Improper use of an extension cord in 114.
- 2. Item 23A1 Combustible materials stored on stove in electric trades.

Storage Bldg. SW Tech – No violations noted.

Small Storage Bldg. – No violations noted.

Large Storage Bldg. – No violations noted.

36173 NYS Rt. 12E Clayton, New York 13624
315-654-5077

OGDENSBURG

Northwest Occ. Center

1. Item 2E2 Rescue window blocked in 143.

5/15 { **NW Tech/Child Care** – No violations noted. Cold storage/power off.

Activity Center

1. Item 12E1 Wire mold pulled off the wall in kitchen.

Storage Bldg. – Northwest – No violations noted.

CANTON

Educational Services Complex

1. Item 12J1 Improper use of an extension cord in 309.

5/14 { **Adult Ed. – IDA Building**

1. Item 12E1 Power strip daisy chained in 2nd. Floor office and 3 locations in the simulator room.
2. Item 12J1 Improper use of an extension cord in simulator room.
3. Item 12K1 Cover plate missing 2nd. floor Office.

Please advise me as to the date of the board meeting for the presentation of this report. You need to notify the public and the fire department as to the time and date of this meeting.

Sincerely yours,

John Warneck